



**NOTES:**

1. ALL PIPING IS TYPE K SOFT COPPER
2. AIR VALVES TO BE INSTALLED AT ALL POINTS BETWEEN OUTLETS ON THE PIPE (HYDRANTS, SERVICES, ETC.) WHERE THE ELEVATION OF THE CROWN OF THE PIPE IS HIGHER THAN THE OTHER OUTLETS.
3. ON 10" & SMALLER PIPES, 1" ASSEMBLY REQUIRED.
4. ON 12" & LARGER PIPES, 2" ASSEMBLY REQUIRED.
5. MAY ALSO BE USED FOR SAMPLING TAP. SAMPLING TAPS TO BE PLACED AT A MINIMUM, AT THE END OF ALL MAINS, AT THE END OF ALL BRANCHES AND AT INTERVALS OF 1/2 MILE FOR MAINS LONGER THAN 1/2 MILE.
6. SEE CURRENT CITY OF SALISBURY WATER & SEWER APPROVED PRODUCTMANUFACTURER'S SHEET FOR APPROVED TYPES LOCATED IN APPENDIX "A" OF THE CITY OF SALISBURY UNIFORM CONSTRUCTION STANDARDS

CITY OF SALISBURY, N.C.      STANDARD DETAIL

DATE: OCTOBER 17, 2006

WATER SYSTEM  
BLOW OFF VALVE

NOT TO SCALE

STANDARD W-7